

Certificate of Conformity

NO.: DAH260225001

DATE: Feb 25th, 2026

To whom it may concern,

Subject: Internal Resistance Confirmation for DAH Batteries

This is to certify that the internal resistance value (SOC 50%, 20°C ± 5°C) of DAH batteries is as follows:

1. DHN-LVWES15-G1(51.2V 280AH) ≤ 25 mΩ.
2. DHN-LVWES10-G1(51.2V 204H) ≤ 25 mΩ.
3. DHN-LVWES05-G1(51.2V 102AH) ≤ 25 mΩ.
4. DH-A05

These values represent the typical internal resistance measured under standard testing conditions stated

above and may vary slightly depending on temperature, state of charge, and measurement method.

Best Regards, Thank you very much for kind confirmation.

Best regards,

DAH New Energy Technology Co. Ltd

E-mail: info@dahsolar.com

Cell: 0551-62115337

Add: NO.1 yao yuan Road, Luyang Industrial Park, Luyang District, Hefei City, Anhui Province, China

